


San Mateo County  
HOJ Traction Elevators (Multiple) Elevators 3 & 7 Only Projects

	<b>Addendum No. 2</b>
	San Mateo County - Department of Public Works 555 County Center, Fifth Floor Redwood City, CA 94063
	RFP: Hall of Justice Traction Elevators (Multiple) Elevators 3 & 7 Only Project
	<b>Addendum Issue Date: Jan. 3, 2023</b>

**INTENT:**

This Addendum is issued by the County of San Mateo to provide for modification and clarification of the Request for Proposals (RFP) for the Hall of Justice Traction Elevators (Multiple) Elevators 3 & 7 Only Project (Project). Proposers shall ascertain prior to submitting its Proposal that it has received all addenda issued. Please clearly note the addendum number and addendum issue date on your proposal.

In the event of a conflict between the terms and provisions of this Addendum and the terms and provisions of the RFP for the Project, the terms and provisions of this Addendum shall control. In all other respects, the RFP for the Project shall remain unchanged and in full force and effect.

1. The Engineer's Estimate of Probable Construction Cost: \$1,775,000.00
2. The Attendance / Sign-in Sheet for the Dec. 13, 2022, Mandatory Pre-bid Meeting & Site Walk can be downloaded via the link below: [San Mateo County – Hall of Justice Traction Elevators \(Multiple\) Elevators 3 & 7 Only Project | County of San Mateo, CA \(smcgov.org\)](https://www.smcgov.org/DocumentCenter/View/13343/San-Mateo-County-Hall-of-Justice-Traction-Elevators-(Multiple)-Elevators-3-&-7-Only-Project-County-of-San-Mateo-CA-smcgov.org)
3. Bid Question: *“The spec calls for flush mount hall stations in the jail car. The walls are concrete. Cutting concrete is expensive, time consuming, loud and dirty. We request that surface mount hall stations be permitted at all landings”*

Addendum Response: Surface mounted hall fixtures will be allowed upon approval in the jail car.

4. Bid Question: *“Can you please confirm that the current emergency power generator has the ability to take on the added load of the elevator being added to the circuit? It was my understanding that elevator number 3 is to become powered by the generator under emergency power conditions. “*

Addendum Response: Elevator #7, not Elevator #3, shall be added to emergency power. Please review Performance Specifications and Drawings. See Electrical Plans for requirements.

**Proposer's Initials and Date:** \_\_\_\_\_