

**REQUEST FOR INFORMATION
FOR
COUNTY OF SAN MATEO**

**LISTED BELOW ARE THE QUESTIONS (Q) SUBMITTED BY
POTENTIAL BIDDERS FOR THE**

PESCADERO HIGH SCHOOL CSA 11 WATER LINE EXTENSION PROJECT

**TOTAL PROJECT APPROXIMATELY 1.27 MILES IN LENGTH
WITH APPURTENANT WORK THERETO
IN COUNTY OF SAN MATEO**

**COUNTY PROJECT NO. PC027
PROJECT FILE NO. 5104**

**THE COUNTY OF SAN MATEO DEPARTMENT OF PUBLIC WORKS
HAS PROVIDED RESPONSES (R) TO THE QUESTIONS BELOW**

Q1. Do you have Union Requirements?

R1. No.

Q2. We manufacture the pipe gaskets including the self restrained gasket HydroGrip (formerly called RieberLok). The HydroGrip gasket makes your pipe to pipe connection a restrained joint with standard C900 pipe. Please see the following link. This gasket takes the place of a bell joint harness.
<https://hultec.com/solution/hydrogrip/>

Will you please accept the HydroGrip selfrestrained gasket for your restrained pipe to pipe joints on the Pescadero HS-11 Waterline Extension PC027.

R2. Yes, substitutions are acceptable for bidding but will be subject to final approval during the construction submittal phase.

Q3. Please confirm if there is or is not a pre-bid meeting, mandatory/non-mandatory for Pescadero High School CSA 11 Waterline Extension Project.

R3. There is no pre-bid meeting.

Q4. What is the estimated construction start date of this project?

R4. Notice to proceed will likely be issued in early July 2025.

All RFI Requests were due by April 24, 2025. The RFI submittal period is now closed. No further responses will be proved for any additional RFIs received after this date.

Updated as of May 1, 2025 at 9:27 AM

G:\Users\utility\water_CSA-11\Pescadero High School New Waterline\AR 5912 Pescadero HS - Prop 1 Project\Bid Process\3_Addendums\Addendum #1\RFI_County Responses_Addendum No. 1.docx