

October 15, 2020

BKF Job No.: 19950168

Robert Pelligrin

225 Demeter St East Palo Alto, Ca 94303 robertpellegrine@yahoo.com

RE: Lot 10 Highlands Estates Project, San Mateo, CA

On September 23, 2020 BKF surveyed the height of the ridge line for the building of the above referenced Lot 10. Our measurements indicate a height of 524.52. The architectural designed elevation per the approved plan set has a Ridge Height of 524.84.

This survey was performed by me or under my direction in conformance with the requirements of the Professional Land Surveyor's Act.

Please contact me with any questions.

Sincerely,

David Jungmann, PLS

Project Manager

650.482.6365 Direct // 408.761.5871 Cell

djungmann@bkf.com

